

**CONFIDENTIAL**

24 NOV 1980

25X1A MEMORANDUM FOR: [REDACTED]  
NFAC/OCR/AS

25X1A FROM: [REDACTED]  
Chief, Field Engineering Branch, RECD/OL (C)

SUBJECT: Floor Loading Survey for Room 1H18, Headquarters

1. A floor loading survey of Room 1H18, Headquarters, was conducted by FEB/RECD/OL during 1978 as a result of a similar request to replace the existing files with seven new power files. Due to the extreme weight of fully loaded power files, a structural analysis of the beams supporting the area was performed.

2. The result of the structural analysis is illustrated on the attached plan. Seven power files may be installed in Room 1H18 as indicated; however, the floor loading in the surrounding areas must be limited to 30 pounds per square foot (psf). This would require limiting the floor loading within area ABCD to tables, chairs, and desks only. All existing safes and files would have to be removed.

3. If any further assistance is required, please do not hesitate to contact C/FEB/RECD/OL on extension [REDACTED]

25X1



25X1A

Att.

Distribution:

OL 0 5255

Orig - Adse

- ✓ 1 - OL/RECD Official
- 1 - OL/RECD/FEB Chrono
- 1 - OL Reader
- 1 - HEB w/att
- 1 - LSD w/att

25X1A OL/RECD/FEB/[REDACTED] (21 Nov 80)

25X1

WARNING NOTICE  
INTELLIGENCE SOURCES  
AND METHODS INVOLVED



**CONFIDENTIAL**